



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx EXA 18.0004X	Page 1 of 4	Certificate history:
Status:	Current	Issue No: 1	Issue 0 (2018-06-21)
Date of Issue:	2022-11-18		
Applicant:	Officine Orobiche S.r.l. Via Giorgio Paglia, 22 I - 24050, Zanica (BG) Italy		
Equipment:	Magnetic Switch, type: T25 XD2		
Optional accessory:			
Type of Protection:	Flameproof enclosure 'db', Protection by enclosure 'tb'		
Marking:	Ex db IIC T6 Gb Ex tb IIIC T85°C Db		

Approved for issue on behalf of the IECEx
Certification Body:

Position:

Signature:
(for printed version)

Date:
(for printed version)

Marino Kelava

Certification Signatory



2022-11-18

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Fiditas Ltd
Slavka Tomerlina 44
HR-10361 Zagreb-Sesvete
Croatia



Fiditas
explosion safety solutions



IECEx Certificate of Conformity

Certificate No.: **IECEx EXA 18.0004X**

Page 2 of 4

Date of issue: 2022-11-18

Issue No: 1

Manufacturer: **Officine Orobiche S.r.l.**
Via Giorgio Paglia, 22
I - 24050, Zanica (BG)
Italy

Manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2011 Explosive atmospheres - Part 0: General requirements
Edition:6.0

IEC 60079-1:2014-06 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

IEC 60079-31:2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

HR/EXA/ExTR18.0006/00

Quality Assessment Report:

IT/CES/QAR16.0002/07



IECEx Certificate of Conformity

Certificate No.: **IECEx EXA 18.0004X**

Page 3 of 4

Date of issue: 2022-11-18

Issue No: 1

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

Magnetic switch type T25 XD2 is an equipment intended for detection of liquid thresholds in tanks. The working principle of the device is based on interaction between a reed switch contained in the enclosure and a float, with a permanent magnet inside, that floats in the process fluid inside a bypass pipe connected to the tank. The measure is performed by commutation of the reed switch. Reed switch contact is a bistable SPDT contact.

The enclosure is an explosion proof, die cast aluminum, Limatherm Mod. XD-JB85 (Certificate IECEx FTZU 09.0028U) with silicone VMQ rubber gasket (-40°C / 150°C). A circle plate bracket allows fastening the magnetic switch to the bypass pipe using stainless steel bands.

Openings in the enclosure, tread M20x1,5, 1/2" NPT-F or 3/4" NPT-F, should be equipped with appropriate certified plugs or cable glands provided that the following minimum requirements are satisfied: Ex db IIC Gb / Ex tb IIIC Db

Rated Voltage: 230 Vac / 200 Vdc

Rated Current: 1A/0.5A

Max process fluid temperature: 250 °C

SPECIFIC CONDITIONS OF USE: YES as shown below:

1. Ambient temperature range of equipment is -40°C up to +70°C.
2. For information on the dimensions of the threaded flameproof joints the manufacturer shall be contacted.



IECEx Certificate of Conformity

Certificate No.: **IECEx EXA 18.0004X**

Page 4 of 4

Date of issue: 2022-11-18

Issue No: 1

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Manufacturer's and applicant's address and QAR reference were updated.

A handwritten signature in blue ink is located in the bottom left corner of the page.